



## FACTORY MUTUAL RESEARCH CORPORATION

### FM APPROVAL – CERTIFICATE OF COMPLIANCE

#### APPROVAL JOB IDENTIFICATION NUMBER: 3009918

The attached Certificate of Compliance has been issued to SENTRAN, LLC by Factory Mutual Research Corporation effective February 21, 2001.

This Certificate of Compliance pertains to all listed SENTRAN load cell models (Please refer to the attached copy of FMRC Certificate of Compliance).

#### APPROVAL RATINGS SUMMARY

- **INTRINSICALLY SAFE:** For use in Classes I, II & III; Divisions 1 & 2; Groups A, B, C, D, E, F & G; Temperature Class T5
- **NONINCENDIVE:** For use in Classes I; Division 2; Groups A, B, C, & D; Temperature Class T5
- **SUITABLE:** For use in Classes II & III; Division 2; Groups F & G; Temperature Class T5 Hazardous (Classified) Locations when installed in accordance with Document No. 14001.

A copy set of Document No. 14001 is attached, along with reference documentation from FMRC relative to the listed Approval Ratings.

For further technical information or for applications engineering assistance, please contact SENTRAN's Applications Engineering Group at (909) 605-1544.